

Cembrit CZ a.s.

Lidická 302
266 38 Beroun 3
Czech Republic

Tel: 00 42 0311 7441111 Fax: 00 42 0311 744248
e-mail: info@cembrit.cz
website: www.cembrit.cz



**Agrément Certificate
No 03/4041**

CEMBRIT SLATES**PRODUCT SHEET 1 — JUTLAND SLATES****PRODUCT SCOPE AND SUMMARY OF CERTIFICATE**

This Certificate relates to Jutland Slates, acrylic-coated fibre-reinforced cement slates.

THIS CERTIFICATE INCLUDES:

- factors relating to compliance with UK Building Regulations where applicable
- factors relating to additional non-regulatory information where applicable
- independently verified technical specification
- assessment criteria and technical investigations
- design considerations
- installation guidance
- regular surveillance of production
- formal three-yearly review.


KEY FACTORS ASSESSED

Strength — the product has adequate strength to resist the loads associated with the installation of the roof or an external wall cladding (see section 4).

Properties in relation to fire — the product will enable a roof or an external wall cladding to be unrestricted under the Building Regulations (see section 5).

Liquid water penetration — the product will resist the passage of moisture into the building (see section 6).

Durability — under normal service conditions the product will provide a durable covering with a service life of in excess of 30 years (see section 8).



The BBA has awarded this Agrément Certificate for Jutland Slates to Cembrit CZ a.s. as fit for their intended use provided they are installed, used and maintained as set out in this Agrément Certificate.

On behalf of the British Board of Agrément

Date of First issue: 22 August 2003
Date of Second issue: 19 October 2007

Greg Cooper: Chief Executive

The BBA is a UKAS accredited certification body — Number 113. The schedule of the current scope of accreditation for product certification is available in pdf format via the UKAS link on the BBA website at www.bbacerts.co.uk

Readers are advised to check the validity and latest issue number of this Agrément Certificate by either referring to the BBA website or contacting the BBA direct.

British Board of Agrément
Bucknalls Lane
Garston, Watford
Herts WD25 9BA

©2007

tel: 01923 665300
fax: 01923 665301
e-mail: mail@bba.star.co.uk
website: www.bbacerts.co.uk

Cembrit CZ a.s.

Lidická 302
266 38 Beroun 3
Czech Republic

Tel: 00 42 0311 7441111 Fax: 00 42 0311 744248
e-mail: info@cembrit.cz
website: www.cembrit.cz



Agrément Certificate
No 03/4041

CEMBRIT SLATES**PRODUCT SHEET 2 — ZEELAND SLATES****PRODUCT SCOPE AND SUMMARY OF CERTIFICATE**

This Certificate relates to Zeeland Slates, acrylic-coated fibre-reinforced cement slates.

THIS CERTIFICATE INCLUDES:

- factors relating to compliance with UK Building Regulations where applicable
- factors relating to additional non-regulatory information where applicable
- independently verified technical specification
- assessment criteria and technical investigations
- design considerations
- installation guidance
- regular surveillance of production
- formal three-yearly review.


KEY FACTORS ASSESSED

Strength — the product has adequate strength to resist the loads associated with the installation of the roof or an external wall cladding (see section 4).

Properties in relation to fire — the product will enable a roof or an external wall cladding to be unrestricted under the Building Regulations (see section 5).

Liquid water penetration — the product will resist the passage of moisture into the building (see section 6).

Durability — under normal service conditions the product will provide a durable covering with a service life of in excess of 30 years (see section 8).



The BBA has awarded this Agrément Certificate for Zeeland Slates to Cembrit CZ a.s. as fit for their intended use provided they are installed, used and maintained as set out in this Agrément Certificate.

On behalf of the British Board of Agrément

Date of First issue: 22 August 2003
Date of Second issue: 19 October 2007

Greg Cooper: Chief Executive

The BBA is a UKAS accredited certification body — Number 113. The schedule of the current scope of accreditation for product certification is available in pdf format via the UKAS link on the BBA website at www.bbacerts.co.uk

Readers are advised to check the validity and latest issue number of this Agrément Certificate by either referring to the BBA website or contacting the BBA direct.

British Board of Agrément
Bucknalls Lane
Garston, Watford
Herts WD25 9BA

©2007

tel: 01923 665300
fax: 01923 665301
e-mail: mail@bba.star.co.uk
website: www.bbacerts.co.uk

Cembrit CZ a.s.

Lidická 302
266 38 Beroun 3
Czech Republic

Tel: 00 42 0311 7441111 Fax: 00 42 0311 744248
e-mail: info@cembrit.cz
website: www.cembrit.cz



Agrément Certificate
No 03/4041

CEMBRIT SLATES**PRODUCT SHEET 3 — WESTERLAND SLATES****PRODUCT SCOPE AND SUMMARY OF CERTIFICATE**

This Certificate relates to Westerland Slates, acrylic-coated fibre-reinforced cement slates.

THIS CERTIFICATE INCLUDES:

- factors relating to compliance with UK Building Regulations where applicable
- factors relating to additional non-regulatory information where applicable
- independently verified technical specification
- assessment criteria and technical investigations
- design considerations
- installation guidance
- regular surveillance of production
- formal three-yearly review.


KEY FACTORS ASSESSED

Strength — the product has adequate strength to resist the loads associated with the installation of the roof or an external wall cladding (see section 4).

Properties in relation to fire — the product will enable a roof or an external wall cladding to be unrestricted under the Building Regulations (see section 5).

Liquid water penetration — the product will resist the passage of moisture into the building (see section 6).

Durability — under normal service conditions the product will provide a durable covering with a service life of in excess of 30 years (see section 8).



The BBA has awarded this Agrément Certificate for Westerland Slates to Cembrit CZ a.s. as fit for their intended use provided they are installed, used and maintained as set out in this Agrément Certificate.

On behalf of the British Board of Agrément

Date of First issue: 22 August 2003
Date of Second issue: 19 October 2007

Greg Cooper: Chief Executive

The BBA is a UKAS accredited certification body — Number 113. The schedule of the current scope of accreditation for product certification is available in pdf format via the UKAS link on the BBA website at www.bbacerts.co.uk

Readers are advised to check the validity and latest issue number of this Agrément Certificate by either referring to the BBA website or contacting the BBA direct.

British Board of Agrément
Bucknalls Lane
Garston, Watford
Herts WD25 9BA

©2007

tel: 01923 665300
fax: 01923 665301
e-mail: mail@bba.star.co.uk
website: www.bbacerts.co.uk

Cembrit CZ a.s.

Lidická 302
266 38 Beroun 3
Czech Republic

Tel: 00 42 0311 7441111 Fax: 00 42 0311 744248
e-mail: info@cembrit.cz
website: www.cembrit.cz



Agrément Certificate
No 03/4041

CEMBRIT SLATES**PRODUCT SHEET 4 – MOORLAND SLATES****PRODUCT SCOPE AND SUMMARY OF CERTIFICATE**

This Certificate relates to Moorland Slates, acrylic-coated fibre-reinforced cement slates.

THIS CERTIFICATE INCLUDES:

- factors relating to compliance with UK Building Regulations where applicable
- factors relating to additional non-regulatory information where applicable
- independently verified technical specification
- assessment criteria and technical investigations
- design considerations
- installation guidance
- regular surveillance of production
- formal three-yearly review.


KEY FACTORS ASSESSED

Strength — the product has adequate strength to resist the loads associated with the installation of the roof or an external wall cladding (see section 4).

Properties in relation to fire — the products will enable a roof or an external wall cladding to be unrestricted under the Building Regulations (see section 5).

Liquid water penetration — the product will resist the passage of moisture into the building (see section 6).

Durability — under normal service conditions the product will provide a durable covering with a service life of in excess of 30 years (see section 8).



The BBA has awarded this Agrément Certificate for Moorland Slates to Cembrit CZ a.s. as fit for their intended use provided they are installed, used and maintained as set out in this Agrément Certificate.

On behalf of the British Board of Agrément

Date of First issue: 19 October 2007

Greg Cooper: Chief Executive

The BBA is a UKAS accredited certification body — Number 113. The schedule of the current scope of accreditation for product certification is available in pdf format via the UKAS link on the BBA website at www.bbacerts.co.uk

Readers are advised to check the validity and latest issue number of this Agrément Certificate by either referring to the BBA website or contacting the BBA direct.

British Board of Agrément
Bucknalls Lane
Garston, Watford
Herts WD25 9BA

©2007

tel: 01923 665300
fax: 01923 665301
e-mail: mail@bba.star.co.uk
website: www.bbacerts.co.uk