


Schedule of Accreditation

issued by

United Kingdom Accreditation Service

2 Pine Trees, Chertsey Lane, Staines-upon-Thames, TW18 3HR, UK

 <p>UKAS TESTING 4544</p> <p>Accredited to ISO/IEC 17025:2005</p>	<h3>Sherwin-Williams Protective & Marine Coatings</h3> <p>Issue No: 005 Issue date: 23 February 2016</p>	
	<p>Tower Works Kestor Street Bolton BL2 2AL</p>	<p>Contact: Miss Carol Fleetwood Tel: +44 (0)1204 521771 Fax: +44 (0)1204 556479 E-Mail: carol.fleetwood@sherwin.com Website: www.sherwin-williams.com/protectiveEMEA</p>
<p>Testing performed at the above address only</p>		

DETAIL OF ACCREDITATION

Materials/Products tested	Type of test/Properties measured/Range of measurement	Standard specifications/ Equipment/Techniques used
FIRE RESISTANT COATINGS and PRODUCTS on steel sections	<p>Fire resistance</p> <p style="text-align: center;">(W) (D) (H)</p> <p>Furnace A – 1.15 * 1.45 * 1.45m</p> <p>Furnace B – 2.10 * 2.10 * 1.50m</p> <p>Furnace C – 1.50 * 2.00 * 1.65m</p> <p>Furnace D – 0.70 * 0.60 * 0.70m</p>	<p>Reduced size, non-loadbearing sections following the methods in :-</p> <p>BS 476:Part 20:1987 BS 476:Part 21:1987 BS EN 1363-1:2012 BS EN 1363-2:1999 BS EN 13381-4:2013 BS EN 13381-8:2013 UL 263:2011 UL 1709:2007</p>
<p>END</p>		